



ADDENDUM #1

ISSUE DATE: October 12, 2022

INVITATION FOR BID

IFB #23-4510-133

Route 10 Watermain Extension Phase I

Department of Budget & Finance

17090 Monument Circle, Suite 137

Isle of Wight, VA 23397

<http://www.Isleofwightus.net>

This Addendum supplements or modifies the original Solicitation noted above and is made part of the Invitation for Bid. This Addendum consists of a total of two (2) pages. The following modifications are included with this Addendum:

This Addendum announces a **NEW BID DATE AND BID OPENING TIME AND DATE.**

The bid due time/date has been changed to **2:00 PM EST, on October 27, 2022.**

The bid opening time/date has been changed to **2:30 PM EST, on October 27, 2022.**

The Invitation for Bid has been revised as detailed below. **Note that a Bid Bond is required, as well as a Performance Bond and a Payment Bond.** Replace pages I-1 to I-32 with the **Attached Pages I-1 to I-32.**

*Page I-1, Bid Due and Bid Opening date revised.

*Page I-4 SCOPE OF WORK section has been revised.

*Page I-6 BID FORM has been revised.

The **Project Manual** has been revised with the inclusion of Section 806 – Horizontal Directional Drilling. Also, by reference, the Hampton Roads PDC construction specification Section 200 is included as part of the Project Manual.

Note the following Question(s) and Answer(s) below:

1. Since wireline installation will be needed to install this pipeline correctly for the HDD, the steering tooling will not be able to achieve the horizontal and vertical curves from station 2000-2700, can the vertical curve be removed and if so will this bore need to be engineered again at the cost to the contractor.

Response: Please see the attached supplemental specification for the HDD which requires the contractor to provide detailed engineering plans for the HDD.

2. Can entry and exit for the HDD angles be changed to 12 degrees if desired.

Response: Yes, as indicated in Addendum #1, HDD supplemental specifications.

3. Can the radius for the HDD be reduced if desired.

Response: Yes, as indicated in Addendum #1, HDD supplemental specification.

Contract Officer: _____

Erin Wishall, Purchasing Agent, ewishall@isleofwightus.net

****AN ELECTRONIC DOCUMENT SHALL BE PROVIDED****

Erin Wishall, Purchasing Agent, is the contract officer for Isle of Wight County with respect to this RFP. All questions and/or comments should be directed to him at ewishall@isleofwightus.net. The respondents to this RFP shall not contact, either directly or indirectly, any other employee or agent of the County regarding this RFP. Any such unauthorized contact may disqualify the offeror from the procurement.