



**ADDENDUM #1**  
**ISSUE DATE: April 12, 2024**

**IFB #24-7110-290**

**Jones Creek Boat Ramp Repairs**

**Department of Budget & Finance**  
**17090 Monument Circle, Suite 137**  
**Isle of Wight, VA 23397**  
<https://www.co.isle-of-wight.va.us/>

This Addendum supplements or modifies the original Solicitation noted above and is made part of the Request for Proposal. This Addendum consists of two (2) pages.

**Contract Officer:** *Erin Wishall*  
Erin Wishall, Assistant Purchasing Agent

*Erin Wishall, Assistant Purchasing Agent, is the contract officer for Isle of Wight County with respect to this IFB. All questions and/or comments should be directed to her at [ewishall@isleofwightus.net](mailto:ewishall@isleofwightus.net) The respondents to this IFB shall not contact, either directly or indirectly, any other employee or agent of the County regarding this IFB. Any such unauthorized contact may disqualify the offeror from the procurement.*

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City/State/Zip: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_

E-mail: \_\_\_\_\_

Print name: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

## Addendum No. 1

**\*The Bid Due Date will remain Friday, 4/19/2024, 3:00 pm\***

### Question and Answer

The following questions and answers are incorporated in the bid:

- Q1 Will the bracing on the bents be on both sides of the piles forming an “X” brace or only on the one side going diagonally?
- A1 The repair drawings are to replace the deteriorated member “in kind”, the bracing on the bents will be only on one side going diagonally.
- Q2 Are existing toe rails on north and south piers to be replaced after new decking installed?
- A2 Yes.
- Q3 Are railings on “L” of South pier to be replaced?
- A3 Yes.
- Q4 Are stringers to be replaced on any of the piers?
- A4 No stringers are to be replaced on the piers.
- Q5 Do you know the weight of the gangway?
- A5 No, the weight of the gangway is unknown.